

Geschoss	Nr.	Raum	Fläche m²	Volumen m³	zu	üb	ab	Pers.	Zuluft Empfehlung m³/h x Person	Zuluft BAFA m³/h x Person	Zuluft gewählt m³/h	Abluft Forderung ASR m³/h x m²	Abluft gewählt m³/h	Luftwechsel 1/n
									15	30		11		
Gerät 1 West-Flügel	02	MZR / Speisesaal	107	294	x		x	32	480	960	500	1177	500	1,70
	01	Windfang	7	20										
	20	Lüftung	12	33	x					0	60			1,82
	22.1	Schrank	13	37			x					148	30	0,81
	22.2	Abstell	10	28			x					110	30	1,09
	23	Sauber-Wä.	8	22			x					87	40	1,83
	24	Wäsche	8	23			x					91	50	2,19
	21.1	WC-Kü	3	7			x					30	30	4,04
	21.2	PuMi	5	15			x					59	30	2,03
	38.2	Flur	50	137		x								
	37	Leiterin	15	42	x			1	15	30	50		50	1,20
	36	Personal	24	65	x			6	90	180	150			2,30
	35	KiWa	12	33										
	34	Garderobe 1+2	19	51	x					0	100			1,96
	33	WC	5	13			x					53	50	3,74
	32	WC	5	14			x					58	50	3,48
	26	Krippe 1	43	118	x		x	14	210	420	150	471	200	1,70
	28	Krippe 2	43	118	x		x	14	210	420	150	470	200	1,70
	27	Sanitär	14	39			x					157	150	3,82
	29	Sanitär	14	39			x					157	150	3,82
	25	Schlafen	30	83	x			14	210	420	200			2,42
	31	Schlafen	30	83	x		x	14	210	420	200	332		2,41
	30	Flur Krippe	44	121		x								
		Gerät 1	522	1435				95			1560		1560	1,09
Gerät 2 Ost-Flügel	10	Abstell	10	28		x								
	11	Einzelförder	10	28			x	2					30	1,09
	9.1	HAR + Heizung	11	29										
	8	Garderobe	10	27										
	12	Flur KiGa	115	315	x					0	80			0,25
	16	Hausmeister	17	46	x						20			0,43
	7	WC	5	13			x					52	30	2,29
	6	Beh.-WC	7	20			x					81	40	1,98
	5	Lager	15	41			x					166	20	0,48
	4	Küche	27	74	x		x	2	30	60	100	297	80	1,35
	19	Gruppe 1	40	111	x		x	16	240	480	300	445	200	2,70
	17	Gruppe 2	41	113	x		x	16	240	480	300	451	200	2,66
	18	Sanitär	21	56			x					226	200	3,55
	15	Gruppe 3	40	111	x		x	16	240	480	300	444	200	2,71
	13	Gruppe 4	40	111	x		x	16	240	480	300	444	200	2,70
	14	Sanitär	21	56			x					226	200	3,54
		Gerät 2	429	1180				68			1400		1400	1,19
		Gebäude	951	2615				163			2960		2960	1,13